

ITS.SC.530 Water Damage Protection



Approved Sept. 10th, 2020
Next Scheduled Review: Sept. 10th, 2025

Procedure Statement

Texas A&M University-Kingsville (TAMUK) protects data center information systems from damage resulting from water leakage by providing master shutoff or isolation valves that are accessible, working properly, and known to key personnel within the facilities department

Reason for Procedure

This Control applies to all TAMUK network information resources. The intended audience for this Control includes all information resource owners, custodians, and users of information resources.

The university protects the information system from damage resulting from water leakage by providing master shutoff or isolation valves that are accessible, working properly, and known to key personnel.

Procedures and Responsibilities

Information resource owners with responsibility over infrastructure equipment shall protect the information resource from damage resulting from water leakage by providing master shutoff or isolation valves that are accessible, working properly, and known to key personnel.

Related Statutes, Policies, Rules or Requirements

-
- 1.) DIR Practices for Protecting Information Resources Assets
-

Contact Office

For More Information, Contact: ITS
MSC 185, 700 University Blvd., Kingsville, TX 78363-8202
Contact Phone: 361-593-2404